

## LEAD-FREE SCHEDULE 40 RED BRASS NIPPLES

**AMERICAN NATIONAL STANDARDS INSTITUTE (A.N.S.I.)**

**ANSI/ASME B1.20.1:** Threads, pipe - general puprose (inch)



- Manufactured in compliance with all applicable ASTM and ANSI Standards
- All unplated nipples have a weighted average lead content of less than 0.25% and are in compliance with the California and Vermont lead-free plumbing requirements
- **ASTM B687-99:** Standard specification for brass, copper and chromium-plated pipe nipples
- Manufactured in compliance with all applicable ASTM and ANSI Standards

\* Lead-Free refers to the wetted surface of pipe, fittings and fixtures in potable water systems that have a weighted average lead content  $\leq 0.25\%$  per the Safe Drinking Water Act (Sec. 1417) ammended 1-4-2011 and other equivalent state regulations.

**MATERIAL:** Red Brass

**SPECIFICATION:** UNS Alloy C23000

**JOB NAME:**

**JOB LOCATION:**

**CONTRACTOR:**

**DATE:**

**ITEM TAG:**

**ENGINEER APPROVAL:**

**DATE:**

**PART NUMBER:**